

**CITY OF BROOKSVILLE  
BROOKSVILLE LANDSCAPE PROJECT  
SR45/US41 PHASES I, II, III  
BID NO.: PR2016-03**

\*\*\*\*\*

**ADDENDUM #1  
Date Issued – March 4, 2016**

\*\*\*\*\*

TO: All prospective proposers and others concerned.

You are hereby notified that this Addendum shall be attached to and made a part of the above named Proposal and Contract Documents, as follows:

This addendum is being issued to address the correction made to the **Minimum Technical Specifications, Page 2 of 4, paragraph 4, section D. "TOPSOIL", item 2, line 4** as highlighted below.

**D. TOPSOIL**

1. Topsoil for landscape work is not available on site and must be furnished as specified.
2. Provide new topsoil that is fertile, friable, natural loam, surface soil, reasonably free of subsoil, clay lumps, brush, weeds and other litter, and free of roots, stumps, stones larger than ½ inch in any dimension, and other extraneous or toxic matter harmful to plant growth. Topsoil shall be obtained from naturally drained sources; shall contain at **least 2.5 percent organic matter**. Acidity shall range from pH 5.0 to pH 7.0 inclusive. Top soil shall be proportioned by volume rather than weight. No site mixing will be accepted.

Acknowledge receipt of the Addendum #1 by signing the document and attaching to Proposal Documents submitted. Failure to do so may subject the proposer to disqualification.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date Acknowledged